

June 14, 2022

Ms. Deedee Antypas
Stockton RWCF
2500 Navy Drive
Stockton, CA 95206

RE: Notice of Final Action - Authority to Construct
Facility Number: N-811
Project Number: N-1212743

Dear Ms. Antypas:

The Air Pollution Control Officer has issued the Authority to Construct permits to Stockton RWCF for a 4,332 bhp Tier 2 emergency standby engine powering an electrical generator at 2500 Navy Drive in Stockton, California. Enclosed are the Authority to Construct permits and a copy of the notice of final action that has been posted on the District's website (www.valleyair.org).

Notice of the District's preliminary decision to issue the Authority to Construct permits was posted on April 12, 2022. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on April 11, 2022. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Samir Sheikh

Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

Mr. Deedee Antypas
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce (209) 557-6400.

Sincerely,

A handwritten signature in black ink, appearing to read "Brian Clements".

Brian Clements
Director of Permit Services

BC:sm

Enclosures

cc: Courtney Graham, CARB (w/ enclosure) via email
cc: Laura Yannayon, EPA (w/ enclosure) via email

Facility # N-811
STOCKTON RWCF
2500 NAVY DRIVE
STOCKTON, CA 95206

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
3. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
4. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
5. **Source Test:** Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source_testing.htm for source testing resources.
6. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at http://www.valleyair.org/busind/comply/compliance_forms.htm.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at
any of the telephone numbers listed below.**

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

AUTHORITY TO CONSTRUCT

PERMIT NO: N-811-28-0

ISSUANCE DATE: 06/13/2022

LEGAL OWNER OR OPERATOR: STOCKTON RWCF
MAILING ADDRESS: 2500 NAVY DRIVE
STOCKTON, CA 95206

LOCATION: 2500 NAVY DR
STOCKTON, CA 95206

EQUIPMENT DESCRIPTION:
4332 BHP KOHLER MODEL KD83V16 DIESEL-FIRED EMERGENCY ENGINE (TIER 2 CERTIFIED) POWERING A 3000 KW ELECTRICAL GENERATOR

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOx emission reduction credits for the following quantity of emissions: 1st quarter - 418 lb, 2nd quarter - 418 lb, 3rd quarter - 418 lb, and 4th quarter - 419 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 8/15/19) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. ERC Certificate Number N-1518-2 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct [District Rule 2201] Federally Enforceable Through Title V Permit
5. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

6. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
9. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rule 4702, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
10. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
11. Emissions from this IC engine shall not exceed any of the following limits: 3.89 g-NO_x/bhp-hr, 0.77 g-CO/bhp-hr, or 0.43 g-VOC/bhp-hr. [District Rule 2201 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. Emissions from this IC engine shall not exceed 0.082 g-PM₁₀/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
17. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 30 hours per calendar year. [District Rules 2201, 4102, and 4702, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
19. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, 40 CFR 60 Subpart IIII, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit