

**AVISO DE UNA DECISIÓN FINAL
PARA LA OTORGACIÓN DE UNA AUTORIDAD PARA CONSTRUIR Y
MODIFICACIÓN SIGNIFICANTIVA DE UN PERMISO MANDATORIO FEDERAL PARA
OPERAR**

POR EL PRESENTE SE NOTIFICA que el Director Ejecutivo del Distrito del Aire ha otorgado permisos de Autoridad para Construir a Vie-Del Winery #1 para la modificación de una caldera de gas natural existente de 60 MMBtu/hr (unidad de permiso C-1344-7) para ajustar el sistema de reducción catalítica selectiva (SCR, por sus siglas en inglés), modelo DNX-929 de Haldor Topsoe existente para cumplir con el límite de emisión de NOx de 2.5 ppmv de la Regla 4320 del Distrito, en 11903 S Chesnut Ave, Fresno.

Todos los comentarios que se recibieron siguiendo la decisión preliminar en este proyecto fueron considerados.

Los comentarios recibidos por el Distrito durante el periodo del aviso público resultaron en la corrección del valor diario calculado del Potencial de Emisión Posterior al Proyecto (PE2) para las emisiones de VOC de 88.7 libras/día a 7.9 libras/día (consulte la página 8 de la evaluación de ingeniería adjunta). Estos cambios fueron menores y no provocaron requisitos adicionales de aviso público, ni tuvieron un impacto sobre la determinación de Mejor Tecnología de Control Disponible o en la cantidad de compensaciones requeridas para la aprobación de este proyecto.

El análisis del Distrito , para Proyecto # C-1220078, está disponible para la inspección del público en http://www.valleyair.org/notices/public_notices_idx.htm, el DISTRITO PARA EL CONTROL DE LA CONTAMINACIÓN DEL AIRE DEL VALLE DE SAN JOAQUIN, 4800 ENTERPRISE WAY, MODESTO, CA 95356, y en cualquiera de las oficinas del Distrito. Para más información en Español, por favor comuníquese con el Distrito al (209) 557-6400.

**NOTICE OF FINAL DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permit to Vie-Del Winery #1 for the modification of an existing 60 MMBtu/hr natural gas-fired boiler (permit unit C-1344-7) to tune the existing Haldor Topsoe model DNX-929 Selective Catalytic Reduction (SCR) system in order to meet the 2.5 ppmv NOx emission limit of District Rule 4320, at 11903 S Chesnut Ave, Fresno.

All comments received following the District's preliminary decision on this project were considered.

Comments received by the District during the public notice period resulted in the correction of the calculated daily Post-Project Potential to Emit (PE2) value for VOC emissions from 88.7 lb/day to 7.9 lb/day (reference page 8 of the attached engineering evaluation). These changes were minor and did not trigger additional public notification requirements, nor did they have any impact upon the Best Available Control Technology determination or on the amount of offsets required for project approval.

The application review, project # C-1220078, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356, and at any other District office. For additional information, please contact the District at (209) 557-6400.